



TEST REPORT

DATE: 10-20-2016

TEST NUMBER: 0232343

CLIENT	Masland Carpets
---------------	-----------------

TEST METHOD CONDUCTED	ASTM F2199 Test Method for Determining Dimensional Stability of Resilient Floor Tile after Exposure to Heat
------------------------------	---



DESCRIPTION OF TEST SAMPLE	
IDENTIFICATION	Calibre' High Performance LVT 5mm
CONSTRUCTION	Vinyl Plank

GENERAL PRINCIPLE

This test method is intended for use in determining the linear change of resilient flooring after being exposed to heat. The dimensional change over 12 inches is reported as the dimensional stability.

TEST RESULTS

IDENTIFICATION	RESULT
Length	-0.003 Inch per 12 inches (-0.03%)
Width	-0.003 Inch per 12 inches (-0.02%)

APPROVED BY:

This report is provided for the exclusive use of the client to whom it is addressed. It may be used in its entirety to gain product acceptance from duly constituted authorities. This report applies only to those samples tested and is not necessarily indicative of apparently identical of similar products. This report, or the name of Professional Testing Laboratory Inc. shall not be used under any circumstance in advertising to the general public.